



川山泵浦

FILE NO. 0

PUMP PERFORMANCE REPORT

MODEL	S0125STA			RATED	
FREQUENCY	60	HZ		16	m
DISCHARGE	4	INCH	100	MM	L/min
OUTPUT	1	HP	0.75	kW	2 P / 3450 RPM
PHASE/VOLTAGE	1	Ø	110	V	DIRECT
RATED CURRENT	A	9.3	INSULATION CLASS		E CLASS

NO	PUMP				MOTOR				
	Flow	Head	Pressure	P.EFF.	Voltage	Current	Input Power	Shaft Power	P.F.
	L/min	m	kg/cm ²	%	V	A	kW	kW	%
1	0	34.04	3.15	0.00	109.8	8.11	0.78	0.62	87.44
2	35.9	24.74	2.22	21.05	110.2	8.77	0.86	0.69	89.23
3	43.5	22.54	2.00	22.77	110.1	8.91	0.88	0.70	89.68
4	52.4	20.14	1.76	23.97	110.1	9.06	0.90	0.72	90.16
5	72.59	2.55	0.00	4.62	110.3	8.35	0.82	0.65	88.79



Tester: Timothy Liu

Validate: