



川山泵浦

FILE NO. 0

PUMP PERFORMANCE REPORT

MODEL	S3125ST			RATED	
FREQUENCY	60	HZ		16	m
DISCHARGE	4	INCH	100	MM	L/min
OUTPUT	0.5	HP	0.37	kW	2 P / 3450 RPM
PHASE/VOLTAGE	1	Ø	110	V	DIRECT
RATED CURRENT	A	5.7	INSULATION CLASS		E CLASS

NO	PUMP				MOTOR				
	Flow	Head	Pressure	P.EFF.	Voltage	Current	Input Power	Shaft Power	P.F.
	L/min	m	kg/cm ²	%	V	A	kW	kW	%
1	0	31.04	2.85	0.00	110.8	5.60	0.57	0.46	92.46
2	26.3	16.84	1.43	15.80	110.9	5.58	0.57	0.46	92.59
3	31.9	15.14	1.26	17.16	110.8	5.60	0.58	0.46	92.69
4	38.5	13.14	1.06	17.83	110.8	5.63	0.58	0.46	92.90
5	52.7	2.55	0.00	4.93	110.9	5.41	0.56	0.44	92.60



Tester: Timothy Liu

Validate: